



### RESCIND OF TIER 1 BOIL WATER ADVISORY

The Colorado Department of Public Health and Environment-Water Quality Control Division (the “Department”) issued a “Boil Water Advisory” for the WALSENBURG CITY OF (the “Supplier”) on **February 1, 2023** due to a **line break resulting in a loss of pressure to the system. Loss of pressure may allow disease-causing organisms to enter the water system.**

Since the “Boil Water Advisory” was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the system and average system chlorine residuals were brought down to normal levels after the flush.
- The Supplier provided a written description of flushing activities and confirmation that the lowest chlorine residual at the ends of the system.
- Confirmation that the samples taken were free from the presence of total coliform bacteria.

Based upon the actions taken by the Supplier, the “Boil Water Advisory” is hereby rescinded. Effective date of this action is **February 3, 2023**. The affected customers should be notified of the lifting of the “Boil Water Advisory.” Public notice of the lifting of the “Boil Water Advisory” should include contact information for the water system and should be provided in a similar manner to which the initial advisory was issued. A template can be created at [wqcdcompliance.com/pn](http://wqcdcompliance.com/pn) under “Problem Corrected”.

For more information, please contact **Gaye Davis** at [cityadmin@walsenburg.org](mailto:cityadmin@walsenburg.org) or **719-738-1048**, or **525 S. Albert St. Walsenburg, CO 81089**.